



## Town of Medley

Office of Capital Projects & Development Services  
7777 NW 72 Avenue, Medley, Florida 33166

Date:	<b>December 20, 2016</b>
Subject:	<b>NW 79 Avenue from NW 77 Street to NW 79 Place Paving and Drainage Imp.</b>
Solicitation Number:	<b>ITB 2017-002</b>
OCPDS Number:	SW-0115
Opening Date / Time:	<b>January 5, 2017</b>
ADDENDUM Number:	<b>3</b>

### ***To all interested proposers:***

The Town of Medley defines a solicitation "Addendum" as an addition to or amendment of the original terms, conditions, specifications, or instructions of a procurement solicitation (e.g. Invitation for Bids, Request for Proposals or Request for Qualifications), including but not limited to questions and answers, which are considered a material part of the solicitation.

### **Please note the following updates:**

Addendum #2 does the following:

**Revisions to the Solicitation Documents as follows (additions underlined, ~~deletions strikethrough~~):**

Attached project manual's pages 2-8, 2-9 and 2-10. Attached revision 01 to the set of plans.

RFI No.	Question	Responses
3-01	522-2 Concrete Sidewalk (6" )	<i>Correct. 6" concrete sidewalk is no longer needed.</i>
3-02	710-11-101 Painted Pavement Markings Standard, White, Solid, 6"	<i>An updated page 2-10 of the project manual will be released in future addendum which includes this pay item.</i>
3-03	710-11-123 Painted Pavement Markings, Standard, White, Solid for Crosswalks and Roundabout, 12"	<i>An updated page 2-10 of the project manual will be released in future addendum which includes this pay item.</i>
3-04	710-11-125 Painted Pavement Markings, Standard, White, Solid for Stop Line Crosswalks, 24"	<i>An updated page 2-10 of the project manual will be released in future addendum which includes this pay item.</i>
3-05	527-2 Detectable Warnings	<i>An update of pages 2-8, 2-9 and 2-10 of the project manual will be released in future addendum which removes duplication of pay items.</i>
3-06	700-1-11 Single Post Sign (F&I Ground Mount, up to 12SF)	<i>An update of pages 2-8, 2-9 and 2-10 of the project manual will be released in future addendum which removes duplication of pay items.</i>
3-07	700-1-12 Single Post, F&I Ground Mount, 12-20SF)	<i>An update of pages 2-8, 2-9 and 2-10 of the project manual will be released in future addendum which removes duplication of pay items.</i>
3-08	Will the CEI be responsible for taking density test on the sub-base and base?	<i>No. Density testing will be the responsibility of the contractor.</i>



## Town of Medley

Office of Capital Projects & Development Services  
7777 NW 72 Avenue, Medley, Florida 33166

3-09	<p>We have received Addendum 2 with the Attached Part 2-8A and Part 2-9, including some existing Items in Part 2-10 , for example: Item 43 Detectable Warnings 100SF vs Item 37 162SF Item 44 &amp; 45, Single Post Sign, 5 &amp; 1 vs Items 39 &amp; 40</p>		<p><b>You should reflect in your bid the latest quantities presented in the addendums. Addendum 3 is taking care of some pay item duplication that was incorrect.</b></p>
3-10	<p>The FDOT allows for optional pipe materials for drainage applications. High Performance HP pipe meets all the FDOT requirements for culverts and French Drains. In addition, the cover is also within the FDOT's design criteria.</p> <p>Traditionally, Optional Pipe Materials are selected by analyzing cover, Design Service Life (DSL), Manning's number, and the soil conditions (pH, resistivity, and other properties). HP pipe is one of the most inert material available for drainage and will meet a 100 year DSL for most applications.</p> <p>Please provide a copy of the soil report and allow the use of ADS HP Storm pipe as an optional pipe material for this project.</p>		<p><b>As discussed in the pre-bid meeting the project restricts the pipe material to RCP. Due to the size of the project, corrosion testing was not performed during the geotechnical exploration.</b></p>

**BID PROPOSAL  
FOR ITB 2017-002**

**NW 79TH AVENUE FROM NW 77TH STREET TO NW 79TH PLACE PAVING AND DRAINAGE IMPROVEMENTS**

No.	Pay Item Number	Description of Work	Unit	Quantity	Unit Price (\$)	Written Unit Price (\$)	Extended Cost (\$)
41	700-1-60	Single Post Sign, Remove	AS	57			
42	706-3	Retro-reflective Pavement Markers	EA	183			
43	710-11-101	Painted Pavement Markings, Standard, White, Solid, 6"	GM	1.3			
44	710-11-123	Painted Pavement Markings, Standard, White, Solid for Crosswalk and Roundabout, 12"	LF	1,998.0			
45	710-11-125	Painted Pavement Markings, Standard, White, Solid for Stop Line or Crosswalk, 24"	LF	162.0			
46	710-11-201	Painted Pavement Markings, Standard, Yellow, Solid, 6"	GM	1.6			
47	710-11-231	Painted Pavement Markings, Standard, Yellow, Skip, 6"	GM	0.6			
48	711-11-123	Thermoplastic, Standard, White, Solid, 12"	LF	691			
49	711-11-125	Thermoplastic, Standard, White, Solid, 24"	LF	54			
50	711-11-224	Thermoplastic, Standard, Yellow, Solid, 18"	LF	18			

Name of Bidder \_\_\_\_\_

Signature of Bidder \_\_\_\_\_



**BID PROPOSAL  
FOR ITB 2017-002  
NW 79TH AVENUE FROM NW 77TH STREET TO NW 79TH PLACE PAVING AND DRAINAGE IMPROVEMENTS**

No.	Pay Item Number	Description of Work	Unit	Quantity	Unit Price (\$)	Written Unit Price (\$)	Extended Cost (\$)
31	430-175-118	Pipe Culvert, Optional Material, Round, 18" S/CD	LF	224			
32	430-175-124	Pipe Culvert, Optional Material, Round, 24" S/CD	LF	144			
33	443-70-4	French Drain, 24"	LF	1279			
34	520-1-10	Concrete Curb and Gutter, Type F	LF	3405			
35	520-3	Valley Gutter, Concrete	LF	190			
36	522-1	Concrete Sidewalk (4" thick)	SY	2114			
37	527-2	Detectable Warnings	SF	162			
38	570-1-2	Performance Turf, Sod	SY	1560			
39	700-1-11	Single Post Sign (F&I, Ground Mount, up to 12SF)	AS	5 10			
40	700-1-12	Single Post Sign, F&I Ground Mount, 12-20 SF	AS	1			

\_\_\_\_\_  
Name of Bidder

\_\_\_\_\_  
Signature of Bidder

**BID PROPOSAL  
FOR ITB 2017-002**

**NW 79TH AVENUE FROM NW 77TH STREET TO NW 79TH PLACE PAVING AND DRAINAGE IMPROVEMENTS**

No.	Pay Item Number	Description of Work	Unit	Quantity	Unit Price (\$)	Written Unit Price (\$)	Extended Cost (\$)
11	110-1-1	Clearing and Grubbing	AC	1.38			
12	120-1	Regular Excavation	CY	1256			
13	120-6	Embankment	CY	400			
14	160-4	Type B Stabilization	SY	2556			
15	285-709	Optional Base Group 09	SY	2556			
16	327-70-6	Milling Existing Asphalt Pavement (1 1/2" Avg. Depth)	SY	5436			
17	334-1-23	Superpave Asphaltic Conc. Traf C, PG 76-22, PMA	TN	<del>578.5</del> 784.4			
18	337-7-74	Asphalt Concrete Friction Course, Traffic C, FC-12.5, PG 76-22, ARB	TN	210.9			
19	425-1311	Inlets, Curb, Type P-1, <10'	EA	4			
20	425-1312	Inlets, Curb Type P-1, >10'	EA	1			

Name of Bidder \_\_\_\_\_

Signature of Bidder \_\_\_\_\_